

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7260-0028:228 Page 1 of 1

CATEGORY: Beam Smoke Detection System

LISTEE: Notifier, One Fire-Lite Place, Northford CT 06472-1653
Contact: Lawrence Flood (203) 484-1200 Fax (203) 484-7309

DESIGN: Models FSB-200 and FSB-200S projected beam smoke detector. Each unit consists of resistors, capacitors, diodes, photo diodes and LED, on a printed wiring board inside an enclosure that has an opening to the outside air. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 15 – 32 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as projected beam smoke detectors for use with Models BEAMMMK, BEAMSMK and BEAMLRK mounting kits (CSFM Listing No. 7300-1209:231) and separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

06-16-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**